



防爆合格证

CONFORMITY CERTIFICATE OF EXPLOSION-PROOF

证号 CE15.2210X
Certificate No.

产品名称
Name of Product

振棒料位开关

型号及规格
Type of Product

Tube-11 I[1]II[2]WA[3]II[4]

防爆标志
Marking

Ex ia II C T6/T5/T4/T3/T2/T1 Ga;
Ex iaD 20 T85°C/T100°C/T135°C/T200°C/T300°C/T450°C

技术文件
Technical Documents

Q/JWVIBRATION06-2014

图号
Drawing No.

Tube-11.00

备注
Note (s)

本证书备注内容详见附件

经对上述产品图样及技术文件的审查和样品的检验,其符合以下标准

By verifying the drawings and technical documents and checking samples, the product complies with the following standards

GB 3836.1-2010 GB 3836.4-2010 GB 12476.1-2013 GB 12476.4-2010

发给: 深圳计为自动化技术有限公司
Issued to:

本证失效日期: 2020-07-21
Date of Expire:

发证日期: 2016-12-06
Date of Issue:

中心印章
Center seal



中心主任
Director

刘红亮

石油和化学工业电气产品防爆质量监督检验中心
Supervision & Test Center of Ex-products of China Petroleum & Chemical Industry

注: 本证仅对与送检样品一致的产品有效

Note: This certificate is only valid for the products that are in accord with sample(s) tested and verified.

中心地址: 中国天津市丁字沽三号路 85 号

Center Add: No.85 No.3 Road DingZiGu Tianjin China Post code: 300131

E-mail: pcec@pcec.com.cn

邮政编码: 300131

Tel/Fax: 022-26651066/26689116

http://www.pcec.com.cn

电话/传真: 022-26651066/26689116